

#28381

February 19, 1971

Lord Phillip Trust

E.S. Phillips Rd.; s. x Braley Rd.

Extention-Apart. House #5

Please install 4" service-3" taker's meter to supply apartment house. Meter: in box on taker's land.

Measures of 4" Mueller Mechanical Gate Valve:

W x 2nd. hyd. on Phillips Park Dr. 299'

N x S line Phillips Park Dr. easement 8'

Main is 5 ft. N x S line Phillips Park Dr.  
easement - south

Work done June 25, 1971

1 - 8" x 8" x 4" Mechanical tee  
1 - 4" Mechanical gate valve - Mueller  
1 - 4" C. I. gate box, regular - complete  
40 ft. of 4" Tyton Cast Iron Pipe, Class 22

Stock supplied and installed by Contractor  
Work inspected by Camara  
Work done June 25, 1971  
No street cuts