

Tel. 9-3311

Harbor View Towers, Ass

July 7, 1971

#28459

Harbor View Towers, Associates
E.s. Acushnet Ave. between School
St., & Walnut St.

Please install 6" C.L.C.I. Fire Supply to
supply Apartment Bldg. A. From hydrant.
Measures of 6" Mueller O-R Gate Valve - A. B.

W x W line	Second Street	32.2 ft.
E x E	" Building	48. 42.8 ft.
N x S	" School Street	3.2 "
W x Center	Hydrant	15.3 6.2 "

Work done July 13, 1971

Main to line is 2 ft.

P	8 ft. of 6" C.I.C.L. Pipe @ 2.76 Tyton	\$ 22.08
	Labor	\$ 89.22
P	1 6" Mueller O-R All Bell Gate Valve	\$ 72.00
P	1 6" C. I. Gate Box, Complete - 224#	\$ 68.54
P	Carting	\$ 10.00
P	16 lbs. Mineral lead @ .24 lb.	\$ 3.84
P	1 lb. Asbestos Yarning	\$ 2.28
	Loader use: 2 hrs. @ 7.00 hr.	\$ 14.00
	Compressor use: 2 hrs. @ 6.00 hr.	\$ 12.00
	Supervision.	\$ 17.84
		\$ 311.80

6 ft. of 6" C. I. Pipe inside

Contractor will maintain the sidewalk cut