

Kenneth E. Strong, Treas., Main St. Wareham, 02571

December 16, 1971

4581 132G

#28576

Brooklawn Nursing Home, Inc.

E.S. Acushnet Ave., N. x Sharon St.

Please install 4" Service 3" Taker's meter to supply nursing home. Meter: inside pit on taker's land. Service from Acushnet Ave.

Measures of 4" Mueller Gate Valve:

N x N line	Sharon St.	981.0 ft.
W x E "	Acushnet Ave.	4.6 ft.
N x S "	Meter box	3.6 ft.
W x W "	" "	8.0 ft.

Work done January 3, 1972

Contractor supplied & installed ALL stock

11.6 ft. - 4" C.I.C.L. Pipe

1 - 4" Mueller Gate Valve Mechanical

1 - 4" Gate Box, reg.

1 - 8" x 8" x 4" Mech. Tee

1 - 4" Bend 1/4 Mech. C.L.

Contractor dug, backfilled & will maintain
trench cuts.

Inspected by John Medeiros

✓
—
226
186

102