

337 Union St.

January 10, 1972

#35 m¹

#28586

225

Field Street Realty Trust

W. S. Field St., S. x Grape St.

Please install 2" Taker's meter copper service to supply Medical center. Meter: inside bldg. Service from: Field St. Main to be extended by taker. 4" Ser. to bldg. - reduced to 2" inside

Measures of 4" ~~MVELER~~ GATE VALVE - MECH.

S x S line	Grape St.	254.0 ft.
E x W "	Field St.	12.0 ft.
S x N "	Bldg.	23.0 ft.
E x E "	Bldg.	58.0 ft.

Main is 14 ft. E x W line.

Work done by Contractor Jan. 24, 1972

Stock Supplied by Water Dept.

1 - 4" C.I. Gate Box, complete 209 lbs. 67.72

Stock Supplied by Contractor

60 ft. - 4" C.I.C.L. Ductile Tyton Pipe

1 - 4" Mueller Mech. Gate Valve

1 - 4 x 4 x 4 Mechanical Tee

Contractor installed all stock - he dug,
and backfilled the trench with his equipment.

P.S.