

9-5592

41 Washburn St. 85

April 24, 1972

#28614

Jere M. Donahue 85

N.S. Washburn St., W. x No. Front St.

Please install 6" C.I.C.L. Fire Supply.

Service from Washburn St. Dep. paid.

Measures of 6" Mueller Tapping Gate Valve:

W x W line No. Front St. 323.3

S x W " Washburn St. 15.6

E x W " Building 21.0

Main is 26 ft. S x N line

Service Installed in same trench as #28613

Work done May 1 & 2, 1972

37' of 6" C. I. C. L. Tyton Ductile	Labor	\$244.78
Pipe @ 2.83 ft. 24' out. 13' ins.		\$104.71
12x12x6" Darling Tapping Sleeve.		\$168.--
6" Mueller Tapping Gate Valve.		\$118.45
6" C. I. Gate Box, Complete @ 224 lbs.		\$ 72.58
Carting.		\$ 20.00
A. P. S. Drilling Machine Use.		\$ 30.00
Compressor use: 3 hrs. @ 6.00 hr.		\$ 18.00
Loader use: 4 hrs. @ 7.00 hr.		\$ 28.00
2 Street cuts: 15'x2½' & 6' x 3'		
@ 1.78 L. ft. + 5.00 ea.		\$ 47.38
1 Sidewalk cut: 8x4' Cement		
@ 5.75 sq. yd.		\$ 20.47
20 lbs. Mineralead @ .24 lb.		\$ 4.80
1½ lbs. Asb. Yarn. @ 2.28 lb.		\$ 2.85
Supervision:		\$ 48.96
		<u>\$928.98</u>