

#28328

June 7, 1973

New Bedford Park Dept.

Brooklawn Park (Acushnet Ave.)

S. x Howard Ave.

Please install 4" C. L. C. I. service to supply
pool. Service from Acushnet Ave.

Measures of 4" Mueller Gate Valve - Tapping:

S x S line Howard Avenue 40.0 ft.

E x W " Acushnet Avenue 16.0 ft.

Main is 18 ft. E x W line

Work done June 7 & 8, 1973

Stock Supplied by New Bedford Park Dept.

97 ft. of 4" Cast Iron Cement Lined Tyton Pipe

80 ft. of 1½" copper tubing, Type K, soft

8"x8"x4" Darling Tapping Sleeve

4" Mueller Tapping Gate Valve

4" Gate Box, complete - 209 lbs. - three

4" C. I. Plug

4" Smith Blair Coupling, Cat. #227-7-4.70

Street cut - to be maintained by Park Dept.

Sidewalk cut - to be maintained by Park Dept.

2-1½" Curb stops - Hays

1-1½" male adapter

1-1½" copper tee

4 - 1½" copper elbows - 90°

Work done by New Bedford Water Dept.

H

ACUSHNET AVE.

9" TAP SLEEVE

4" TAP GATE

97 FT 4" C.S.

4" PLUG 1 1/2" HOLE

1 1/2" CURB STOP (SHOWER)

PIPE SHOWER 63 FT 1 1/2" COP

1 1/2" CURB STOP FILLER

1 1/2" COP PIPE 12 FT POND FILLER

~~Tapping Gate Measure~~ ~~Service~~ ~~Card~~

1 1/2" Curb Stop Measure - Shower:

S x S line	Howard Avenue	56.0
W x W	" Acushnet Avenue	82.2
E x E	" Wall (Pool)	3.8

1 1/2" Curb Stop Measure - Filler:

S x S line	Howard Avenue	57.0
W x W	" Acushnet Avenue	81.2
E x E	" Wall (pool)	4.8

