

227 Acushnet Ave.

April 2, 1974

#29160

John S. Cruz

W.S. #227 Acush. Ave. N x Russell St.

Please install  $3/4$ " cu. service to supply  
1 family home. Meter inside collar wall; re-  
places  $5/8$ " Ser. #963 to be discontinued.

Measures of  $3/4$ " Curb Stop:

|               |             |           |
|---------------|-------------|-----------|
| N from        | Russell St. | 211.0 ft. |
| E from W line | Acush. Ave. | 6.3 ft.   |
| N from N line | House       | 1.9 ft.   |

Work done September 25, 1974

|                                            |    |              |
|--------------------------------------------|----|--------------|
| 7 ft. - 3/4" Copper tubing by City @ 1.80: | \$ | 12.60        |
| Labor. . . . .                             | \$ | 33.70        |
| 1 - 3/4" Corporation : . . . . .           | \$ | 5.75         |
| Carting. . . . .                           | \$ | 10.00        |
| B-100 Mueller Tapping Machine Use.         | \$ | 12.00        |
| 2 3/4" Meter cplg. @ 2.00 ea. . .          | \$ | 4.00         |
| Loader Use: 2 hrs. @ 7.00 hr. . .          | \$ | 14.00        |
| Compressor Use: 1/2 hr. @ 6.00 hr. .       | \$ | 3.00         |
| St. cut: 6' x 3' Warrenite @ 1.70:         |    |              |
| + 5.00 . . . . .                           | \$ | <u>15.68</u> |
|                                            | \$ | 110.73       |

NOTE: This service was installed from the main to the curb stop. The former service #963 was already renewed from the curb stop to inside cellar with 3/4" copper.