

#29289

53
N.B. Redevelopment

21 So. Sixth St.

May 1, 1975

N.B. Redevelopment Authority

Elm St. Parking Garage

Please install 6" C.L.C.I. FIRE SUPPLY
to supply garage. Service from Elm Street.

Measures of 6" Gate Valve:

W x W line No. Second St.	23.0 ft.
N x S line Elm St.	18.8 ft.
W x E line Bldg.	20.0 ft.
S x S line Bldg.	32.3 ft.

Main is 22 ft. N x S line

Work done Jan. 16, 1975

FEDERICO SUPPLIED THE STOCK & INSTALLED IT -
AND SUPPLIED THE LABOR.

29.6 ft. - 6" Ductile C.I. Pipe (22 ft. out:
7.6 ft. ins.)

1 - 30 x 30 x 6" Tee, M.J. Class 250

1 - 6" Smith M.J. Gate Valve

1 - Gate Box, regular pattern

Federico dug, backfilled & will maintain the
trench.