

#29296

May 14, 1975

Murray Goldberg

Greater N.S. Reg. Voc. Tech. H. S.

W.s. Ashley Blvd. S x Dewey St.

130C  
130C

Please install 12" FIRE SUPPLY to supply  
Vocational School. Service From Ashley Blvd.

Measures of 12" Tapping Gate Valve

E x W line Ashley Blvd.

14.0 ft.

S x S line Dewey St.

382.0 ft.

Work done 1975

36" x 12" Mueller Tapping Sleeve  
12" Mueller Tapping Gate Valve  
8" Gate Box, complete

All Stock supplied & installed by Contractor-

M. Goldberg

Corrected Measures

March 3, 1989

W.S. Ashley Blvd. S x Dewey St. Ser. # 29296-12"

S x S line Dewey St.	371.0 ft.
----------------------	-----------

N x N line Pine Grove Cemetery wall	7.5 ft.
-------------------------------------	---------

N x center 30" gate cover	24.0 ft.
---------------------------	----------

E x center drain cover	12.0 ft.
------------------------	----------

In driveway - Constantine Bldg.

J. Rodrigues

