

Tel. 9-3281
#29308

8/1/75

Bayview Realty

10

Bayview Realty

N.s. Apponegansett St., W x Rodney Fr. B.

Please install 8" C.L.C.I. to supply manufacturing plant. ~~xx~~ Service from Apponegansett St.
Complete loop with 6" sprinkler system.

Measures of 8" Gate Valve:

E x E line Swan St.	215.5 ft.
N x S line Apponegansett St.	17.0 ft.
W x W line Bldg. (gate)	6.5 ft.

FIRE SUPPLY

Work done by Franklin Contractors

8" A.P. Smith Mech. Gate Valve

12x 8" A.P. Smith Tee

12" lead joint

All stock supplied & installed by Contractor.