

536 Granite St. 59
Braintree 02184

29394

6/7/76

Peabody Construction Co.

S.s. North St.; E x Purchase St.

Please install 8" C.L.C.I. to supply apartment complex.

Measures of 8" Smith Gate Valve, Mech. Jt.

N x S line North St. 26.4 ft.

E x W line Purchase St. 25.5 ft.

S x N line Bldg. 23.0 ft.

W x W line Bldg. 21.5 ft.

Work done April 29, 30, 1975

FIRE SUPPLY

Federico Const. Co. supplied & installed all
Stock:

17.7 ft. - 8" Ductile Iron Pipe Class 2
1 - 12" x 12" x 8" C.I.C.L. Class 250 Mech. Jt
2 - 8" Smith Gate Valve, Mech. Jt. Tee
2 - Buffalo Gate Boxes
2 - 8" C.I.C.L. Class 250 1/4 Bends, Mech. Jt.

Federico dug, backfilled & will maintain
trench.

SEE SKETCH

#29394

S.S. North St. E x Purchase St.

Measures of 8" Post Indicator Valve inside
property line:

N x S line North St.	23.3 ft.
E x W line Purchase St.	43.4 ft.
S x N line Bldg.	26.9 ft.
W x W line Bldg.	3.7 ft.

Measures of 12 x 12 x 8" Tee - for High Rise

N x S line North St.	26.4 ft.
E x W line Purchase St.	21.5 ft.

