

Tel. 9-6451

# 29438

8/27/76

Paul G. Cleary Co.

P.O. Box D-807

New Bedford, Mass.

G. S. A.

52

W.s. Sixth St.; S x Middle St.

Please install 2" copper to supply Federal  
Bldg. Meter inside cellar wall above floor.  
Service from Middle St.

Measures of 8" Smith Gate Valve, Mechanical:

W x W line Sixth St. 137.0 ft.

N x S line Middle St. 10.0 ft.

CHECKED 3/12/80 or

Main is 1 1/4 ft. N x S line.

Work done March 9-11, 1975

FEDERICO SUPPLIED & INSTALLED ALL STOCK

18 ft. - 8" C.I. Class 2 Ductile Pipe  
1 - 8" x 8" x 8" C.I.C.L. Class 250 Tee  
1 - 8" Smith Gate Valve, Mech. Jt.  
1 - Buffalo Gate Box  
(8" gate roddeed to 8" tee)

Federico dug, backfilled & will maintain  
trench.