

✓ # 29504 3/11/77

c/o Amvest Inc.
P.O. Box J-4203

Bayberry Inc.

N.W. Cor. Oakdale St. & W. Hill Rd. 73

Please install $1\frac{1}{2}$ " copper to supply 4-plex.
Meter within 3' of inside entry wall. Service
from Oakdale St. Bldg. # 29

Measures of $1\frac{1}{2}$ " Curb Stop:

W x W line West Hill Rd.	42.0 ft.
S x N line Oakdale St.	6.2 ft.
W x E line Bldg.	28.0 ft.
S x S line Bldg.	21.5 ft.

Main is 14 ft. N x S line.

Work done October 1977

51.3 ft. - 1½" Copper tubing
(36' out: 15.3' ins.)

8" x 1½" Saddle

1½" Corporation Mueller

1½" Curb Stop Mueller

Barboza Const. supplied & installed all
stock

Barboza Const. dug, backfilled & will
maintain trench.

Insp. A. Camara

\$ 4.62

Turn on charge

\$ 5.00

\$ 9.62

Measures of 1½" Corporation

W x W line West Hill Rd.

42.0 ft.

W x Sline Oakdale St.

6.2 ft.

14