

29514

3/11/77

Bayberry Inc.
c/o Amvest Inc.
P.O. Box J-4203

73

Bayberry Inc.

S N.W. Cor. Carriage Dr. & Rockway St.

Please install $1\frac{1}{2}$ " copper to supply 4-plex.
Meter within 3' of entry wall. Service from
Rockway St. Bldg. # 39

Measures of $1\frac{1}{2}$ " Curb Stop:

W x W line Carriage Dr.	41.5 ft.
N x S line Rockway St.	6.0 ft.
N x W line Bldg.	30.0 ft.
N x N line Bldg.	21.5 ft.

Main is $1\frac{1}{4}$ ft. N x S line.

Work done Oct. 3, 1977

31.5 ft. - 1½" Copper tubing
(14' out: 17.5' ins.)

8" x 1½" Saddle P.A.C.

1½" Mueller Corporation

1½" Mueller Curb Stop

Barboza Const. supplied & installed all
stock:

Barboza Const. dug, backfilled & will
maintain trench.

Insp. A. Camara	\$ 4.62
-----------------	---------

Turn on charge	\$ 5.00
----------------	---------

11 x Sline Rockway St. 13.6 ft.	\$ 9.62
---------------------------------	---------

Measures of 1½" Corporation:

W x W line Carriage Dr. 42 ft.