

Tel. 994-3561

P. O. Box N-1176

July 6, 1978

#29660

Singer Heating Co.

s. s. Maple St., W. x Park St.

Please install 4" C.I.C.L. FIRE SUPPLY to
supply Intermediate Care Facility. Service from
Maple St. Work to be done by contractor.

Measures of 4" Gate Valve:

W from W line Park St. 73.0 ft.

N from S line Maple St. 12.0 ft.

Work done July 13, 1978

Franklin Const. installed service.

OK/60

Stock supplied & installed by Contractor

14 ft. - 4" C.I.C.L. Ductile Pipe

(14' out:

6 x 6 x 4 Mueller tapping sleeve

4" Mueller Tapping Gate Valve

Caldwell #10 Gate Box #664, complete

Franklin dug, backfilled & will maintain trench

Tapping Machine Use:

4" Tap.	\$ 75.00
Turn on Charge	\$ 7.50
Insp. John Medeiros.	\$ 38.70

\$ 118.70

25

121.20