

Tel. 7-4575

12 Coffin Ave.
Blvd.

August 30, 1978

#29676 NE Samuel Barnett Blvd. & John Vertente
Cor. Isotronics, Inc. 133

✓ Please install 4" C.I.C.L. service to supply
industrial plant. Meter in building above floor
to be done by contractor.

Measures of 4" Darl. Tapp. Gate Valve:

N x 16" Gate on Vertente Blvd. N x
S. Barnett Blvd. 383.0 ft.
E x Edge of road on Vertente Blvd. 2.5 ft.

Measures of 16" x 16" x 4" Tapp. Sleeve:

N x 16" Gate on Vertente Blvd. N x
S. Barnett Blvd. 383.0 ft.
E x Edge of road on Vertente Blvd. 0 ft.

Contractor Lemieux Engineering supplied &
Installed all stock:

16" x 16" x 4" Mueller Tapping Sleeve

4" Darl. Tapping Gate Valve, Mech.

2 - 16" lead joints

1 - 4" lead joint

66 ft - 4" ductile

Water Dept. tapped pipe:

Tapping Machine A.P. Smith Use	\$ 75.00
--------------------------------	----------

Compressor use:	6.00
-----------------	------

Labor Insp. A. Camara	22.18
-----------------------	-------

Turn on Charge	7.50
----------------	------

\$	110.68
----	--------

Work done Nov. 8, 1978

Contractor dug, backfilled & will maintain