

1213 Purchase St.

53

March 9, 1979

#29756

Harbor Development Commission

S. E. cor. Piers 3 & 4

Please install 2" copper service to supply submerged hydrants. Service & meter installed by contractor.

Measures of Submerged Hydrant (Service)

Meter Pit & Wheel Valve

N x S line Bulkhead	52.0 ft.
W x E line Bulkhead	88.0 ft.
N x S line Bulkhead	33.6 ft.
S x Darl. Hyd.	25.5 ft.

NOTE: This meter pit controls 2 hydrants.

Work done Oct. 12, 1978

Measures of Submerged Hydrant:

W x Bulkhead Road A	107.7 ft.
N x Bulkhead Road A	3.6 ft.

Stock supplied & Installed by Wes Construction

31 ft. - 2" Copper tubing

2" Mueller Corporation

2" Wheel Valve

2 1/8" Flush Hydrant Mueller A 24039 w/one 2 1/8"  
hose nozzle

Contractor dug, backfilled & will maintain  
trench.

Insp. by A. Camara