

1213 Purchase St.

March 9, 1979

#29757

Harbor Development Commission
N. E. cor. Piers 3 & 4

53

Please install 2" copper service to supply submerged hydrants. Service & meter installed by contractor.

Measures of 2" Wheel Valve & Submerged Hyd.
Meter Pit & Wheel Valve:

S x Bulkhead	89.0 ft.
W x Bulkhead	17.1 ft.

Submerged Hyd.

S x Bulkhead	89.0 ft.
W x Bulkhead	3.6 ft.

Work done Sept. 26, 1978

Stock supplied & Installed by Wes Construcion

22.5 ft. - 2" Copper tubing

2" Mueller Corporation

2" Wheel Valve

2 1/8" Flush Hydrant Mueller A 24039 w/one

2 1/2" Hose Nozzle

Contractor dug, backfilled & will maintain
trench.

Insp. by A. Camara