

Tel. 996-8507 P. O. Box F-745, N. B. 02742

August 15, 1979

59

✓ #29804 Maritime Terminal

W.S. Frontage Rd., S. x Hillman St.

Please install 8" CIGL FIRE SUPPLY to supply
freezer bldg. From Frontage Rd. By contractor
-they will supply pipe.

Measures of 8" Gate Valve:

S x S line Hillman St.

336.0 ft.

E x W line Frontage Rd.

11.0 ft.

Work done Sept. 5, 1979

Insp. by A. Camara

D.W.White Const. tapped 16" main & installed
16 x 16 x 8 tapping sleeve & 8" gate

Stock:

- 1 - 16 x 16 x 8 USP Tapping Sleeve
- 1 - 8" U.S. Tapping Gate Valve
- 2 - 16" Lead Joints

All work done Sumner & Dunbar of Canton, Mass
for D.W.White Const.

D.W.White dug, backfilled & will maintain
trench.

13 ft. - 8" C.I.C.L. Pipe (main to prop line)

Labor (Insp.) \$ 5.27

Turn on charge \$ 7.50