

Tel. 997-1766

403 County St., N. B.

January 16, 1980

#29842

Roger R. Lacoste

59

SW cor. Purchase & Maxfield Sts.

Please install 8" C.I.C.L. FIRE SUPPLY to
supply office building. From Maxfield St.
D. W. White contractor.

Measures of 8" Gate Valve:

E x E line Pleasant St.	59.0 ft.
N x S line Maxfield St.	2.5 ft.
E x W line Foundation	9.7 ft.
N x N line Foundation	27.5 ft.

Work done January 28, 1980

This 8" service was installed by Federeico Const. for a future service some time in 1975. Service was up to property line.

D.W. White Installed & supplied all stock from property line to bldg. Service reduced to 6".

Insp. J. Rodrigues,	\$	6.32
Turn On charge.	\$	<u>7.50</u>
	\$	13.82