

Attn: Peter Economos 455 County St. 02740

63

April 23, 1980

#2985 3 City of New Bedford School Dept.  
W. S. Lindsey St., N. x Maxfield St.  
(Sargent Field)

Please install 6" C.I.C.L. service to supply  
fire hydrant. To come from Lindsey St. ALL  
MATERIAL USED TO BE RETURNED TO WATER DEPT. BILL  
SCHOOL DEPT. per E. Rodrigues.

Measures of 6" Gate Valve, Mech.

S x S line Smith St. 156.0 ft.

E x W line Lindsey St. 14.5 ft.

Main to property line 18ft. E x W line.

Work done May 2, 1980

Installed a 6" x 6" x 6" Mech. Tee at the main with 18" of 6" C.I.C.L. Ductile pipe and a 6" Dresser #162 Transition cplg. on the north side of the tee.

Installed remainder of stock in this order:

39' - 6" C.I.C.L. Ductile Pipe

1 - 6" Mueller Gate Valve, Mech.

1 - Caldwell #10 style 664 gate box, compl.

164 ft. - 6" C.I.C.L. Ductile Pipe

4 1/2" Amer-Darl. 6" R.V. 1S 2H Quik Fix Hyd #J

2 - 6" threaded rods - 5/8"

1 - 6" Bell Joint Clamp

St. cut: 6' x 3' Warr.

Side. cut: 8' x 3' Blacktop

see sketch.



