

24 West Howell St., Dorcehster, MA 02125

November 21, 1980

31

#29905 M. F. Foley Co.

#77 NE cor. Wright St. & MacArthur Dr.

Please install 6" C.I.C.L. FIRE SUPPLY service
to supply fish processing plant. From Wright
St. Contractor to do work.

Measures of 6" Gate Valve, Mech.

E x E line Mac Arthur Dr. 128.0 ft.

N x N line Wright St.(ins. p.l.) 4.0 ft.

W x E line Bldg. 6.0 ft.

S x S line Bldg. 17.0 ft.

Installed by Contractor

Campanelli installed 8" service from main to property line in 1968.

No inspector on job - not notified

Turn on charge. \$ 7.50

