

Tel.-

414 County St., N.B. 02740
SeaLect Foods c/o James Ambrose

66

#29990

December 2, 1981

S.S. Antonio Costa Ave. ExH. Melville Blvd.

Please install 4" CLCI serv. to supply mfg.
plant. From A. Costa Ave. 4" serv. reduced to 3"
inside. Taker's meter in bldg. above floor. D.
W. White contractor to do work.

Measures of 4" Dresser Mech. Gate Valve

E x E line H. Melville Blvd.	503.0 ft.
N x S line A. Costa Ave.	10.0 ft.
E x W line Bldg.	5.0 ft.
N x N line Bldg.	50.0 ft.

Main is 18" N x S line.

Work done Dec. 9, 1981

D.W.White Const. installed & supplied all stock:
12" x 12" x 4" Tee, Mech.
4" Dresser Gate Valve, Mech.
1 - #10 Caldwell Gate Box, complete
16 ft. - 4" C.I.C.L. Ductile Pipe

see 10" #29989 for sketch

Inspection	\$	17.76
Turn on charge	\$	<u>25.00</u>
	\$	42.76