

Tel.

Universal Roofing & Sheet Metal

P.O. Box N-1122, N.B. 02746

Nov. 15, 1982

#30055 N.S. Nauset St., W x Purchase St. 102
973

Please install 6" C.L.C.I. fire supply to supply office lbdg. & shop. From Nauset St., No meter fire supply. Milson Engineering to install & furnish stock.

Measures of 6" U.S. Tapping Gate Valve:

E x E line Myrtle St. 172.5 ft.

N x S line Nauset St. 18.6 ft.

Main is 36 ft. S x N line.

Sumner & Dunbar Tapped 24" main.

Work done by Milson Eng. Nov. 24, 1982

Contractor supplied & installed all stock:
36 ft. - 6" CIGL Ductile Pipe
1 - 24" x 24" x 6" Tapping sleeve, p.j.
1 - 6" U.S. Tapping gate valve
1 - #10 Caldwell Gate Box, complete

Measures of Tapping Sleeve:

E x E line Myrtle St.	172.5 ft.
N x S line Nauset St.	17.5 ft.

Reduced to 4" inside of property line.

Turn on charge.	25.00
Inspection - J. Rodrigues	124.80
	149.80