

Tel. Pilgrim Fish, P.O. Box E-735, N.B., 02742
March 2, 1984

#30143 N.S. South St. W x Hassey St.

Please install 4" CLCI service to supply ice house.
From South St., meter in bldg. above floor. Raymond
Davignon ~~to~~ install service & dig trench.

Measures of 4" Tapping Gate Valve:

W x W line Hassey st.	235.5 ft.
N x S line South St.	14.5 ft.
E x W line Bldg.	41.5 ft.

Main is 14 ft. N x S line.

Work done March 8, 1984 by Franklin Corp.

Franklin Const. Supplied & installed all
stock:

14 ft. - 4" C.I.C.L. Ductile Pipe (out)
8" x8" x4" Tapping sleeve
1 - 4" Tapping gate valve
1 - #10 Gate Box, complete

Turn on charge.....\$15.00

PILGRIM
FISH

8 FT. - 4" PIPE UNDER
SEWER

48" SEWER PIPE

4" 1/8 BEND

2.6 FT. - 4"

4" 1/8 BEND

1.5 FT. - 4"

4" TAPR. GATE

8" WATER

8x8x4

SOUTH

ST.

30143-4"

PILGRIM

FISH

WATER ST.

