

Tel. 993-7269

Lighthouse Rest. & Lounge
(Frank Costa)

37

123 MacArthur Dr., N.B. 02740

March 26, 1984

#30147

123 W.S. Mac Arthur Dr. N x Conway St.

Please install 1½" copper serv. to supply restaurant & lounge. From MacArthur dr. Meter inside cellar wall. Ed. Reynolds to install.

Measures of 1½" curb stop:

N x N line Conway St.	606.0 ft.
E x W line MacArthur Dr.	7.0 ft.
N x S line Bldg.	3.0 ft.
E x e line Bldg.	12.0 ft.

Main is 14 ft. E x W line.

Work done June 29, 1984

Frank Corp. supplied & installed all stock:

14 ft. - 1½" Copper tubing (14' out:

1 - 1½" corporation tap

1 - 1½" curb stop

1 Roadway Box, compl.

16" x 1½" Service saddle D.S.

D-4 Drilling machine.....	\$	25.00
---------------------------	----	-------

Labor.....	\$	29.69
------------	----	-------

Turn on charge.....	\$	15.00
---------------------	----	-------

	\$	69.69
--	----	-------

Tel. 993-7269

Lighthouse Rest. & Lounge (Frank Costa)
123 MacArthur Dr., N.B. 02740

March 26, 1984

#30147 123 W.S. MacArthur Dr. N x Conway St.

Please install 1½" copper serv. to supply restaurant & lounge. From MacArthur Dr. Meter inside cellar wall. Ed. Reynolds to install.

Measures of 8" Gate Valve:

N x N line Conway St. 612.0 ft.

E x W line MacArthur Dr. 9.0 ft.

This 8" service was installed in 1988 by Campanella from the main to the property line. Contractor installed 1½" from property line to bldg. March 27, 1984

*Completed
provided
per
Campanella*

42
37

Contractor supplied & installed all stock:

8" x 1½" Double Strap Service Saddle

1 - 1½" Corp. tap

1 - 8" Pipe Clamp

2 - 5/8" x 16" rods

1 - 2" x 14" strap

Tap location:	E x E side Bldg.	3 ft.
	N x S side Bldg.	9 ft.
	W x 8" gate	11 ft.

Turn on charge.....\$ 15.00

Inspection.....\$ 8.98

\$ 23.98

NOTE: Contractor tapped 8" stub.

N

16" MAC ARTHUR DR.

EXISTING 8" GATE

30147

8" PIPE CLAMP
CAP BLOW OUT!

EXISTING
SOLID CAP

8" x 1 1/2" S BOLT
1/2" TOP

