

37
el. Frank Costa 123 MacArthur Dr., N.B.

June 21, 1984

#30173 W.S. MacArthur Dr. N x Conway St.

Please install 4" Fire Supply CLCI to supply restaurant. From MacArthur Dr. Reduce 8" stub @ prop. line. 1½" dom. to be re-tapped @ main. Frank Corp. to install.

Measures of 8" Gate Valve:

N x N line Conway St. 612.0 ft.

E x W line Mac Arthur Dr. 9.0 ft.

Work done July 16, 1984

Used 8" future service installed in 1968
by Campanelli

No inspector - This service was found connected
on July 16, 1984

Turn on charge.....\$ 25.00