

el. Claremont Dev. Assoc. inc. 628 Pleasant St.

Oct. 31, 1985

52

30347 E.S. Pleasant St. S x Bridge St.

Please install 8" CLCI FIRE SUPPLY. From Pleasant St.
Junner & Dunbar to tap main.

Measures of 8" Mu. tapping gate valve, mech.

N x N line Middle St. 210.0 ft.

W x E line Pleasant St . 10.0 ft.

S x hydrant S x RT 6 ramp 54.0 ft.

Wo rk done Nov. 19, 1985

Sumner & Dunbar tapped 30" main with a
30" x 8" Tapping Sleeve
poured lead; #10 Gate Box, compl. w/extension
8" Mu. Tapping Gate Valve, Mech.
18 ft. - 8" CIGL Ductile Pipe (to prop. line)

Inspection.....	\$ 35.44
Turn on charge.....	\$ 25.00
	<u>\$ 60.44</u>

K. R. Rezendes dug, backfilled & will
maintain trench.