

tel. ✓

Claremont Dev. Assoc., Inc., 628 Pleasant St

Oct. 31, 1985

NB 02740

#30348 E.S. Pleasant St. S x Bridge St.

52

Please install 6" CLCI serv. 4" taker's meter to supply apt. commercial complex. From Pleasant St. Meter inside cellar wall. Reduce to 4" just inside prop. line. Sumner & Dunbar to tap main.

Measures of 6" Met. Tapping Gate:

N x N line Middle St. (E.S.)	218.0 ft.
W x E line Pleasant St.	10.0 ft.
S x hydrant S x Rt 6 ramp	46.0 ft.

Work done November 7, 1985

Sumner & Dunbar tapped 30" with a
30" x 6" Tapping Sleeve
poured lead
6" US Met. Tapping Gate Valve
18 ft. - 6" CIGL Ductile pipe
(bell of pipe cut off for
6" x 4" Reducer, Mechanical

Inspection	\$	70.88
Turn on charge.....	\$	25.00
		<hr/>
	\$	95.88

K. R . Rezendes dug, backfilled &
will maintain trench.