

Tel 758-4915(Cape Bldgs.)

Roth Textile Engraving Corp
699 Tarkiln Hill Rd. NB02745

March 3, 1986

125A

#30490 N.E.cor. Tarkiln Hill Rd. & Lambeth St.

Please install 8" Ductile pipe to supply industrial
plant. Service to come from Tarkiln Hill Rd. Sumner &
Dunbar to tap. FIRE SUPPLY.

Measures of 8" Dresser (MH) Tapping Gate, Mech.

W x W line Kings Hwy. 426.0 ft.

S x N line Tarkiln Hill Rd. 29.0 ft.

W x E line Bldg. 25.0 ft.

S x S line Bldg. 61.6 ft.

E x E line Bldg. 27.6 ft.

Main is 32 ft. S x N line.

Work done June 17, 1986

Hoadley Co. supplied & installed all material -
also tapped main:

36" x 36" x 8" Tapping sleeve (Steel with epoxy
coated)

8" Dresser (MH) Tapping gate valve, mech.

1 - #10 Roadway Gate Box, compl.

8" x 6" reducer (located 30' N x gate)

-----32

32 ft. - 8" CIGL Ductile pipe (32' out:8" pipe -
29.6 ft. - 6" pipe ins)
reduced to 6" inside prop. line.

Inspection.....\$ 31.04

Turn on charge.....\$ 25.00

\$ 56.04

Cape Bldg. dug, backfilled & will maintain trench