

✓ Tel. 996-3986 Mass. Gas & Elec. 435 Coggeshall St. NB

March 24, 1986

#30499 E.S.Mt. Pleasant St. S & Downey St. 123"

Please install 8" CIGL FIRE SUPPLY to supply commercial
bldg. From 8" main in Mt. Pleasant St.

Measures of 8" Gate Valve:

S x S line Downey St.	1066.0 ft.
W x E line Mt. Pleasant St.	3.1 ft.
N x N line Bldg.	22.0 ft.
W x W line Bldg.	91.0 ft.

Main is 6 ft. W x E line.

Work done April 23, 1986

Atlantic Design & Const., Plymouth Ma.
installed and supplied all stock:-

8" x 8" x 8" Tee, Mech.
8" Mueller Gate Valve
8" Rockwell #441 Cast cplg.
6 ft. - 8" Ductile Pipe

Contractor dug, backfilled & will maintain
trench

Inspection (A. Hunt).....	\$	117.44
Turn on charge.....	\$	15.00
	\$	132.44

pd Check #10274