

Tel.

N.B... t. for Savings, 174 Union St. NB02740

March 27, 1986

55

#30504 W.S. Rockdale Ave. between Mill & North Sts.

Please install 4" ductile FIRE SUPPLY to supply bank & retail complex. From North St. Has sewer. D.W. White to install.

Measures of 4" Tapping Gate Valve:

W x W line Rockdale Ave.	160.0 ft.
N x S line North St.	13.0 ft.
E x W line Bldg.	3.0 ft.
N x N line Bldg.	13.0 ft.

Main is 14 ft. N x S line.

Work done April 8, 1986

Red Hed tapped main.

Contractor supplied all material.

8" x 8" x 4" Tapping Sleeve, Mech.

4" Tapping Gate Valve, Mech.

1 Roadway Gate Box, complete

Remainder of service was backfilled
before inspection could be made.

D W White dug, backfilled & will maintain
trench.

Insp. (M. Rose).....	\$ 8.18
----------------------	---------

Turn on charge.....	<u>\$15.00</u>
---------------------	----------------

	\$23.18
--	---------