

Tel. 

Town of Freetown, c/o Joh Campeau
9 Ken Petty Rd., Assonet, MA 02702

#30513 Middleboro Rd. @ Beaver Dam

Please install 12" service - 8" ductile main line.
From 12" stub at beaver dam. Meter i pit at beaver dam.
Frank Corp to install.

Measures of 8" Gate Valve Mueller:

N x 48" main at Beavers Dam 5.8 ft.

Work done May 21, 1986

NO MAP TO
PLOT

Meter in Pit:

Rockwell Turbo Meter & Trap #1190733
W- 3500

See main pipe sheet for work done.

Frank Cor. supplied & installed all material

Frank Corp. dug, backfilled & will maintain
trench.