

✓ Tel.

N.B. Municipal Airport

Feb. 19, 1987

123

#30737 N.S. Airport Rd. E x Shawmut Ave.

Please install 6" CLCI FIRE SUPPLY to supply garage.
From Airport Rd. Milson Eng. - Sumner & Dunbar to make
tap.

Measures of 6" Tapping Gate Valve, Mech.

S x hydrant S x Terminal 118.5 ft.

W x W line Bldg. 19.0 ft.

S x S line Bldg. 2.5 ft.

Work done Feb. 17, 1987

Sumner & Dunbar, Inc. tapped main - 8" main on
Paul J. Dreisbach D r. for Airport Bldg.

8" x 8" x 6" Tapp. Sleeve US, Mech.
6" US Gate Valve, Mech.

Service installed by Milsen Eng..

J.F. Luiz, Excavator