

Tel.. 995-2205

James Holding, 1399 Phillips Rd. NB

May 15, 1987

125

#30779 S.S. Old Plainville Rd. W x Mt. Pleasant St.

Please install 2" copper serv. to supply 12 unit condo
From Old Plainville Rd. TAKER'S METER in bldg. above
floor. Sumner & Dunbar to tap. (units 13-24).

Measures of 2" Curb Stop:

N x N line Lang St. 287.0 ft.

On South line Bldg.

E x E line Bldg. 25.0 ft.

In line with hydr. North of hydr. (Dar.) 8.0 ft.

Box: W x 6" plastic gas main 1 ft.

Need to stop box 15 ft.

Work done June 24, 1987

Sumner & Dunbar Tapped main:
All stock supplied by Owners Contractor:

36" x 2" Service Saddle

2" Copporation tap

2" Curb Stop

1 Buffalo Gate Box, compl.

40 ft. - 2" Copper tubing (15' out: 25' ins.)

Insp.....\$ 7.78
Turn on charge.....\$15.00

\$22.78

Costa Bros. dug, backfilled & will maintain
trench. Permit

Change of measure
Old Plainville Rd.

Dec. 1, 1987
Ser. #30779-2"

Change W x W line Bldg.

25.0 ft.

to: E x E line Bldg.

25.0 ft.

