

Tel. 996-6892

Wamsutta Warehouse c/o Nat.
Wholesale, 61 No. Front St. NE

Feb. 24, 1988

#30939 N.W. cor. Wamsutta St. & Front St. 18

Please install 8" CICL Fire Supply. From
Wamsutta St.

Measures of 8" T apping Gate Valve, U.S. , Mech.

W x W line No. Front St. (NS) 248.0 ft.

S x N line Wamsutta St. 13.0 ft.

W x E line Bldg. 16.0 ft.

S x S line Bldg. 37.5 ft.

Work done March 2, 3, 1988

Sumner & Dunbar tapped main. Mike Ricardo dug &
installed service.

Service laid to inside building in this order:
All material supplied by owner except 8" pipe to be
returned: * *RET. 4-21-88*

16" x 8" US Tapping sleeve, mech. jt.

8" US Tapp. Gate Valve, Mech. Jt.

1.0 ft. - 8" Ductile pipe

1 - 8" x 12" Offset (up) M.J. (strapped to gate) 3.0
ft. long

18.0 ft. - 8" ductile pipe Bell cut off

8" x 12" Offset (up) M.J. 3.0 ft. long

8.0 ft. - 8" ductile pipe

18.0 ft. - 8" ductile pipe to inside building

1/4 Bend 8" and 8" riser

Insp.....\$ 9.77

Turn on charge.....\$ 25.00

\$ 34.77