

Tel. Samuel Barnet Blvd. Corp. c/o C. Franklin
May 16, 1988 4385 Acushnet Ave. NB 02745
#31036 N.S. Barnet Blvd. E x Town Line 133³
Please install 6" CLCI FIRE SUPPLY to supply mfg.
plant. Service from Road B.

Measures of 6" Mu. Gate Valve, Mech. Tapping

W x W line Vertente Blvd.	1197.0 ft.
S x N line S. Barnet Blvd. Ext.	67.0 ft.
E x W line Building	5.0 ft.
S x S line Bldg.	173.0 ft.

Main is 68 ft. S x N line
Work done June 13, 1988

Stock supplied by Contractor:

16" x 16" x 6" Mueller Tapping Sleeve, M.J.

6" Mueller tapping gate valve, M.J.

1 - #10 Roadway gate box, compl.

6" ductile pipe (68' out: 105' ins.)

Riani installed tapping gate 5/25/88 - inspected

Frank Corp installed water mains 6/10/88 - not insp.

Insp. (for tap only).....	\$ 9.77
Turn on charge.....	\$ 25.00
	\$ 34.77

Frank Corp. dug & will maintain trench.