

Tel.

49 Hassey St., Inc. 49 Hassey St., NB

May 19, 1988

#31039 S.W. cor. Conway & Hassey Sts.

FIRE SUPPLY <sup>37</sup>

Please install ~~CLCI~~ serv. to supply fish plant & storage. From Conway St. 729

Measures of 8" Gate Valve:

E x E line Cape St. 249.0 ft.

N x S line Conway St. 11.0 ft.

W x sidewalk bound 8.0 ft.

Work done Dec. 28, 1988

This service was picked up at existing 8" branch at property line.

Original service was installed in 1968 by Campanelli as a future service to the line.

-----

From existing bell, 2.0 ft. - 8" pipe popped in  
1 - 8" Ductile 45° s.east  
55 ft. - 8" pipe

1 - 8" 90° (1/4 bend) south  
10 ft. pc. - 8" pipe to north building wall.  
Nemasket Const supplied & installed all stock.

Insp.....	\$	10.78
Turn on charge.....	\$	25.00

---

\$ 35.78