

Tel. 995-5202

Sean F. Daly, 835 Tarkiln Hill Rd.

May 25, 1988

NB 02745

#31043 E.S. Plainville Rd. N x Tarkiln Hill Rd. *125*

Please install 8" CLCI to supply condo dev. From Plainville Rd. EMERGENCY CONNECTION ONLY — MUST STAY IN OFF — POSITION.

Measures of 8" Gate valve: Mueller, m.j.

N x Tarkiln Hill Rd. 693.0 ft.

W x stone wall 7.0 ft.

N x stone wall 10.0 f t.

Work done June 16, 1988

Stock supplied & installed by Contractor:

1 - 8" x 8" x 8" Tee, mech.

8.7 ft. - 8" ductile pipe

8" 1/4 Bend, mech.

54 ft. - 8" Ductile pipe

8" 1/8 Bend, mech. -----

3 ft. - 8" ductile pipe----- under sewer drain

8" 1/8 Bend, mech. -----

3 ft. - 8" ductile pipe

8" 1/8 Bend, mech.

7 ft. - 8" ductile pipe

8" 1/8 Bend, mech.

22 ft. - 8" ductile pipe

8" Gate valve, mech. Mu.-----

Insp.....\$ 9.77

Turn on charge.....\$ 25.00

\$34.77
total