

Lee Bulgaris, PO BOX L-86, NB 02745

Aug. 9, 1988

#31094 E.S. Welby Rd. E xt. N x Welby Rd.

132 E

Please install 6" ductile FIRE SUPPLY. From Welby Rd.
LINE SERVICE ONLY. Street Obst. Permit #

Measures of 6" Gate Valve:

N x N line Welby Rd. (E &W)	502.0 ft.
E x W line Welby Rd. Ext. (N & S)	18.0 ft.
S x N line Building	26.5 ft.
W x W line Bldg.	86.0 ft.

Work done Aug. 1988

Laid to East line by K. R. Rezendes
Extended from line to building by B. Smith 9/26/90

Contractor KR Rezendes supplied all stock:

6" Ductile Pipe

8" x 6" Anchor Tee

6" Gate Valve, Mech.

1 Gate Box, compl.

Service has (S.E.) 45° 1/8 Bend E x gate 47.0 ft..

Also goes in building 24.0 ft. S x gate, 55.0 ft. S x N
line Bldg.

Line pressure tested from inside bldg. to 6" valve at 150
lbs. PSI for 1 hr. by B. Smith (Test good) J. Rodrigues
9/27/90

Inspection
Turn on charge

\$	15.00
\$	25.00
	<hr/>
	40.00