

Tel. 999-4100

Howland Mills Realty Tr.

651 Orchard

Sept. 22, 1988

NB

St.

#31169

W.S. Orchard St. N x Cove Rd.

19

Please install 4" CLCI ser. to supply a restaurant.

Service from Orchard St. Meter inside cellar wall.

Street Obstruction Permit # 579

Measures of 4" Tapping gate valve, mech.

N x N line Cove Rd. 539.0 ft.

E x W line Orchard S t. 17.0 ft.

N x N line bldg. 8.0 ft.

E x E line bldg. 57.0 ft.

Main is 18 ft. E x W line.

Work done Oct. 3, 1988

(S x hydrant 4 ft.)

Sumner & Dunbar, Inc. tapped main & supplied stock:

10" x 10" x 4" Tapping sleeve, mech.

4" Tapping Gate Valve, mech.

65 ft. - 4" Ductile Pipe (18' out: 47' ins.)

Insp.....	\$	9.77
Turn on charge.....	\$	15.00
		<hr/>
	\$	24.77

Prestige H0mes dug & will maintain trench.