

Tel. 471-1700

Astra Corp.

133³
P.O. box 440
Quincy, 02269

9/30/88

by DeLoid Associates

#31189 N.S. Samuel Barnet Blvd. W x John Vertente Blvd.

Please install 8" CLCI FIRE SUPPLY to supply a
commercial bldg. from S. Barnet Blvd.

Street Obstruction Permit #

Measures of 8" Gate Valve:

W x W line J. Vertente Blvd.

1657 ft.

W x hydrant

36 ft.

S x S line Bldg.

198.0 ft.

Work done Oct. 5, 1988

D.W. White supplied all material. Sumner & Dunbar,
tapped main.

16" x 16" x 8" Tapping sleeve, Mech

8" Mu. gate valve, mech.

1 - #10 Gate Box, compl.

2 - 1/8 Bends, mech. - to go under culvert. pipe will
stay deep to go under building.

Insp.....	\$	10.78
Turn on charge.....	\$	<u>25.00</u>
	\$	35.78