

Tel. 997-9401

My Bread Baking Co.
10/18/88

229 Coffin Ave
N.B. 02746

#31220 S.S. Collette St. E x Church St.

98

Please install 6" CLCI FIRE SUPPLY to supply a retail store. from 6" main in Phillips Ave. Frank Corp. is the contractor. Street Obstruction Permit # 744

Measures of 6" Mu. tapping gate valve, Mech:

W x E line Onoko Lane 8.0 ft.

N x S line Phillips Ave. 19.0 ft.

S x N line bldg. (Payne Cutl.) 11.5 ft.

E x E line bldg. (Payne Cutl.) 20.5 ft.

Main is 18 ft. N x S line.

Work done Nov. 15, 1988

Tapped by Riani & Sons
No pipe off this gate yet

6" x 6" x 6" Mueller tapping sleeve, MJ
6" Mueller tapping gate valve, MJ

Insp.....	\$ 10.78
Turn on charge.....	\$ 25.00
	<hr/>
	\$ 35.78

Frank Corp. to maintain trench

New Service - Addittional Info Dec. 5, 1988
S.S. Collette St. E x Church St. Ser. # 31220- 6"

Frank Corp. extended 6" from newly installed gate northerly 22 ft. to a 6" 1/4 Bend and then westerly into property. From the prop. line westerly 41 ft. to a 6" 1/4 Bend and then northerly to tie into existing fire supply.

Insp. by A . Pacheco

五

五

4

1891
1892
1893
1894
1895
1896
1897
1898
1899
1900