

Tel. 999-5629

Sam Elias, Inc.

330 Collette St.

10/27/88

by Norman LeBlanc

N.B. 02746

98

#31225 N.E. cor. Church St. & Coffin Ave.

Please install 6" CLCI FIRE SUPPLY to supply a commercial bldg. from Church St. Frank Corp. is the contractor.

Street Obstruction Permit No: 744

Measures of 6" Mu. tapping gate valve, Mech.:

S x S line Collette St. 170.0 ft.

E x W line Church St. 20.0 ft.

S x S line Bldg. 23.5 ft.

N x 4" gate 4.0 ft.

Main is 18 ft. E x W line.

Work done Nov. 15, 1988

Service tapped by Riani & Sons for Frank Corp.

Stock supplied by Contractor:

8" x 8" x 6" Mueller tapping sleeve, M.J.

6" Mueller tapping gate valve, M.J.

4.7 ft. - 6" ducti~~o~~e pipe - at this time on gate E.S.

Insp.....	\$	10.78
Turn on charge.....	\$	25.00
	\$	35.78

Frank Corp. to maintain trench.