

Tel. 997-1515 ext. 2004 S.L.H. Property Inc. 101 Page St.

10/31/88 *4525* c/o John B. Day N.B. 02740

#31238 W.S. ~~#4449~~ Acushnet Ave. N x Sassaquin Ave. *no map*

Please install 6" CLCI FIRE SUPPLY to supply a nursing home. sprinkler system Street Obstruction Permit # from easement - Sassaquin Ave. North

Measures of 6" gate valve inside easement:

measures taken from East Wing of Bldg. complex:

E x E line Bldg. 3.0 ft.

S x S line Bldg. 6.0 ft.

Work done Sept. 16, 1988

All stock supplied & installed by Contractor.

Excavation by Cornerstone Exc.

| | | |
|---------------------|----|-------|
| Turn on charge..... | \$ | 25.00 |
| Insp..... | \$ | 10.78 |
| | | <hr/> |
| | \$ | 35.78 |

Measures taken by M. Rose