

Tel. 999-2981      Field Street Realty Tr.      225 Field St.  
11/1/88      by Carol Nunes      N.B. 02740

#31240      W.S. Field St. S x Grape St.      35

Please install 4" CLCI FIRE SUPPLY to supply a medical  
bldg. from Field St. Standon Contracting will do the  
work. Street Obstruction Permit No: 747

Measures of 4" Tapping gate valve, mech:

S x S line Grape S t.	242.0 ft.
E x W line Field St.	12.0 ft.
N x S line Bldg.	46.5 ft.
E x E line Bldg.	27.5 ft.

Main is 14 ft. E x W line.  
Work done Dec. 2, 1988

Riani tapped water main.

Standon Const. supplied & installed all material  
in this order:

4" x 4" x 4" Tapping Sleeve, Mech.

1 - 4" Mu. tapping gate valve, mech.

4 ft. 0-4" Ductile pipe

1 - 4" x 6" Increaser, Mech.

18 ft. - 6" Ductile pipe

6" 1/4 Bend, Mech.

13 ft. - 6" Ductile pipe

6" 1/4 Bend, Mech.

4 ft. - 6" Ductile pipe

4 ft. - 6" Ductile pipe into building

Insp.....\$ 9.69

Turn on charge.....\$ 15.00

\$ 24.69

# 31240-4" F.S.



