

Tel. 999-1371

Compass Bank by Steve Pelletier, D.W.

12/12/88

791 Purchase St. N.B. Ma 02740 White

#31274 E.S. Braley Rd. N x Theodore Rice Blvd. *1364*

Please install 8" ductile iron fire supply to install
a commercial complex. from Braley Rd. Street Obstruction
Permit # *912*

Measures of 8" Mu. tapping gate valve, Mech. *no map
not plotted*

N x N line Theodore Rice Blvd.

23.0 ft.

E x W line Braley Rd.

29.0 ft.

Main is 45 ft. *W x E*
~~E x W~~ line.

Work done Dec. 13, 1988

D.W. White Const. supplied & installed all stock:

12" x 12" x 8" Mu. tapping sleeve, Mech.

8" Mu. tapping gate valve, mech.

1 - #10 Gate Box, compl.

8" ductile pipe (45' out:

Sumne & Dunbar tapped service.

Insp.....	\$	10.78
Turn on charge.....	\$	25.00
	\$	35.78

D.W. White Const. dug & will maintain
trench.

#31274 E .S. Braley Rd. N x Theodore Rice Blvd.

12" x 8" Tapping gate

N x B.S. N. l. Rice Blvd.

23.0 ft.

E x B.S. W. L. Braley Rd.

29.0 ft.

