

Tel. 999-1913

2/21/89

cf 650

Edward J. Sylvia

105 Nauset St.

B/B/A Airport Landing N.B. Ma 02746

#31309 E.S. Mt. Pleasant St. S x Downey St.

123"

Please install 8" CLCI (fire supply) to supply a
bed-spread mill outlet. from Mt. Pleasant St.

Corner Stone Excavating is the contractor.

Measures of 8" Mu. Gate Valve, Mech.

S x S line Downey St. 871.0 ft.

W x E line Mt. Pleasant St. 3.0 ft.

N x N line Bldg. 91.0 ft.

Main is 8 ft. W x E line.

Work done Feb. 22, 1989

Note: 2" gas main 1 ft. W x gate valve.

Cornerstone Excavating installed the following material in this order:

8" x 8" x 6" Tee, Mech. on existing main in sidewalk

16" of 6" ductile pipe

8" x 6" Reducer,-Increaser, Mech.

16" of 8" ductile pipe

8" mueller gate valve, mech. (5' E x tee)

Contractor to return 8" Mueller gate valve, mech.

was never returned - removed from Inv. 4/2/90

Insp.....\$ 15.00

Turn on charge.....\$ 25.00

\$ 40.00

Cornerstone dug & will maintain trench.