

Tel. 997-4511 Ext. 2297 School Dept. 455 County St.

8/7/89

Antonio Braz N.B. Ma 02740

#31360 N.E. cor. Madeira Ave. & Earle St.

104

Please install 6" CLCI (fire supply) to supply the  
Ottiwell School. ~~from Earle St.~~ Hathaway St.

Measures of 6" Darling Gate Valve, Mech.

E x E line Madeira Ave. 63.0 ft.

N x S line Hathaway St. 17.0 ft.

W x NW cor. Ottiwell School 15.0 ft.

N x N cor. Ottiwell School 38.0 ft.

Main is 18 ft. N x S line.

Work done Aug. 24, 1989

Cut out a 5 ft. piece on Hathaway St. and installed a 6" x 6" x 6" tee, with 2 ft. nipples on each side with 2 - 6" Rockwell #441 cast cplgs.:

S x tee installed:

2 ft. pc. - 6" ductile pipe

6" Darling gate valve, mech.

163 ft. - 6" ductile pipe with a  
6" plug at end.

-----

Could not make tap on Earle St. due to the big sewer about 1 ft. north of water main 48" sewer, therefore, this service was tapped on Hathaway St. and heads south & will go in a closet on the south side of the modular bldg. according to Mr. Braz.

All stock supplied by Water Dept. -ordered from *RED*  
Bay State Supply to be returned to City. *9-3-89*  
*-3-2.*

15

Leimert St.

# 31360 - 6" F.S.

15'

6'

ENTRANCE

OTWELL SCHOOL

