

Tel. 992-7359

10/13/89

Marvin Dolinsky

Davy's Locker

1480 Rodney Fr. Blvd.  
New Bedford, Ma 02744

#31441 E.S. #1480 Rodney Fr. Blvd. S x Norman St.

12

Please install 6" CLCI fire supply to supply a restaurant.

Service from Rodney Fr. Blvd. Benchmark Excavating-contr.

Measures of 6" Mu. tapping gate valve:

S x S line Norman St. 49.4 ft.

W x E line E. Rodney Fr. Blvd. 17.5 ft.

W x W line Bldg. 57.0 ft.

Work done Oct. 26, 1989

Hoadley & Sons tapped & Installed in this order:

12" x 6" Mu. tapping sleeve, mech.

1 - 6" Mueller tapping gate valve, mech.

2 ft.- 6" Ductile pipe

1 - 6" 45° Bend, ductile (north east & up slightly -  
to bring line up 2.5 from tapping gate level which  
is 6 ft. deep.

6 ft. - 6" ductile pipe

1 - 6" 45° Bend, ductile, mech. (east)

All Rodded - friction clamps

Center of main to 2nd Bend east - 8 ft.

-----

Inspection.....15.00

Turn on charge.....\$25.00

40.00